

Fire Retardancy Codes

Meets:	IEC 60 754-1/-2 (or NES 713)	IEC 61 034 (or NES 711)	IEC 332-1	IEC 332-3-24	UL 1685/CATV (or CM)	UL 1666/CATVR (or CMR)	MSHA Part 7, Subpart K Title 30 CFR
Requirements:	smoke emission: halogen free, not corrosive (toxicity index)	low smoke emission (smoke index)	flame retardant	fire retardant	vertical tray flame test	riser cable test	mining cable test
Abbreviation in the Cable Name:							
J	X						
FX	X	X	X				
F	X	X	X*				X
R	X	X	X	X	X	X	

* Pending Test